



CALIPATRIA - NPDES  
R7-2005-0085

### Monthly eSMR SUMMARY

#### Expected Requirements:

##### M-INF-1

Biochemical Oxygen Demand (BOD) (5-day @ 20 Deg. C)	1/month	mg/L
Total Suspended Solids (TSS)	1/month	mg/L

##### M-INF-2

Biochemical Oxygen Demand (BOD) (5-day @ 20 Deg. C)	1/month	mg/L
Total Suspended Solids (TSS)	1/month	mg/L

#### Using Narratives Tab:

##### M-001

Wastewater shall not have an E. coli concentration in excess of a log mean of Most Probable Number of 126 MPN per 100 milliliters (based on a minimum of not less than 5 samples for any 30-day period).

#### Using Pre-Calculated Tab:

NA

#### Using Raw Data Tab:

##### M-001

BOD5 @ 20 Deg. C, Percent Removal		1/month	%
Phosphate, Total (as P)	1 / Month	mg/L	
Orthophosphate, Total (as P)	1 / Month	mg/L	